



TDCJ Risk Management's Training Circular

Volume 12 Issue 10

Risk Management Issues

October 2012



October Fire Prevention



FIRE TYPES

Class A: Involves the burning of paper, cloth, wood or plastics, etc. (solids that are not metal)



Class B: Flammable liquids, such as gasoline, oils, or other flammable gasses



Class C: Electrical current or electrical devices



Class K: Kitchen (i.e. cooking oils) – to only be used after suppression system discharges. Posting for this type of extinguisher are required in areas where they may be used.



BE FIRE SMART!

When dealing with fires, it is extremely important to know the different types of fires and the appropriate type of extinguisher required for each fire type.


TYPES OF FIRE SUPPRESSION EQUIPMENT

Multi-purpose "ABC" Dry Chemical Fire Extinguishers – come in many different sizes. Normally these will be 5-10 pound fire extinguishers found in various locations. Can be used on Class A, B, and C fires.

Class "K" Kitchen Fire Extinguishers – Wet chemical fire extinguishers for use with kitchen appliances. Discharges a fine mist that helps prevent grease splash and fire re-lash while cooling the appliance. This type of fire suppression equipment shall only be used after the existing cooking equipment automatic system protection has

been discharged.

Standpipe Hose – is mounted on a hose reel in a fixed location on TDCJ units, on the wall of a dormitory, department, or on a cellblock run. Hard rubber hose that sprays a fog or straight stream pattern of water. Only to be used on Class A fires.



Hose Cabinet – containing a soft rubber hose, usually found in administrative areas. The hose is folded in loops and must be pulled from the rack entirely to remove kinks before turning on the water. Only to be used on Class A fires.



The following steps should be followed when responding to incipient stage fire (when they are small and controllable with fire extinguishers):

- Sound the fire alarm and call the fire department, if appropriate.
- Identify a safe evacuation path before approaching the fire. Do not allow the fire, heat, or smoke to come between you and your evacuation path.
- Select the appropriate type of fire extinguisher.
- Discharge the extinguisher within its effective range using the **P.A.S.S.** technique (pull, aim, squeeze, sweep).
- Back away from an extinguished fire in case it flames up again.
- Evacuate immediately if the extinguisher is empty and the fire is not out.

Evacuate immediately if the fire progresses beyond the incipient stage.



USING FIRE EXTINGUISHERS (P.A.S.S)



Pull pin – this allows you to activate the extinguisher

Aim – hold hose and point at base of fire

Squeeze – the trigger mechanism to release the agent

Sweep – back and forth at the base of the fire

FIRE EXTINGUISHER INSPECTION

1. Is each extinguisher in its designated place, clearly visible, and not blocked by equipment, coats, or other objects that could interfere with access during an emergency?
2. Is the nameplate with operating instructions legible and facing outward?
3. Is the pressure gauge showing that the extin-

guisher is fully charged (the needle should be in the green zone)?

4. Is the pin and tamper seal intact?
5. Is the extinguisher in good condition and showing no signs of physical damage, corrosion, or leakage?
6. Is the extinguisher in good condition and showing no signs of physical damage, corrosion, or leakage?
7. Have all dry powder extinguishers been gently rocked top to bottom to make sure the powder is not packing?



NOTE:

If you did not answer yes to all of these questions, have the extinguisher fixed or replaced

IMMEDIATELY!

FIRE ALARMS

Know where manual pull stations are located in your workplace. Never assume a sounding alarm is just a drill.



FIRE PREVENTION

When properly utilized, inspections are an effective method of eliminating hazards and an educational opportunity for employees and offenders.



Regular and periodic inspections can identify fire hazards and unsafe practices that may pose a threat to the safety of individuals within a specific area.

- Housekeeping is one of the easiest forms of fire prevention.
- Flammable liquids should only be stored in approved containers. Chemicals with a flash point less than 100 degrees must be stored in an approved flammable storage cabinet. Never

store combustibles inside any concerns or deficiencies or on top of flammable storage cabinets.

- No open flames should be produced near flammable materials. The use of candles is prohibited.
- Electrical circuits should not be overloaded. Use only appropriate 3-wire extension cords and plug them directly into an outlet. Never "piggy-back" or "daisy chain" extension cords and power strips. If electrical equipment or cords feel hot, unplug them and discontinue their use until cleared by an electrician.
- Appliances should be in the OFF position when unattended.
- Report hazards in the workplace to a supervisor. Do not use equipment that is unsafe.
- Store excess materials and equipment out of the range of fire exits to prevent blocking or tripping.
- Do not store materials in such a manner that would block sprinkler heads, fire suppression equipment, or emergency lights.

FIRE DRILLS

It is to be understood that the purpose of fire drills in offender living areas is to ensure that assigned staff understand their duties and responsibilities, that the emergency key system is functional, that locks and doors are operational, and



Fire drills shall be run in all housing areas at least once per quarter per shift. All other areas are required to have a drill ran at least quarterly.

EVACUATION PROCEDURES

- Be familiar with fire evacuation procedures. Also familiarize yourself with the primary and secondary evacuation routes in your work area. Know the unit/department process for obtaining emergency keys if applicable.
- Know where fire suppression equipment is located and understand their use in the event it is needed to assist with the evacuation process.



- Each shift/department should have a means for accounting for all persons

- in their respective areas. Frequent functional and table-top fire and evacuation drills will ensure all effected individuals are familiar with their roles and responsibilities, as well as safe evacuation procedures in the event of an actual emergency.
- Have someone designated to notify local emergency response.
- Never assume an activated alarm or fire evacuation is a drill.
- **Don't be a hero.**

HOT WORK

Any time welding, grinding, or other types of work that produce a flame or spark is performed outside an approved hot work area, a Hot Work Permit is required.



Ensure there is an appropriate fire extinguisher available for the work being performed.

After any hot work is completed, a fire watch must be implemented for a time of no less than 30 minutes to ensure a fire does not start due to the hot work.


AWARENESS

Fire safety and prevention awareness is one of the most crucial components to a fire safety program.

Knowing how to identify fire hazards before they result in a fire can save lives and serious property damage or loss.



Training should be conducted at least annually in the prevention of fires, fire preparedness procedures, fire evacuations, fire drill procedures, and fire suppression.



References:

- RM-04 TDCJ Employee/Offender Safety Training
- RM-05 Emergency Management
- RM-10 Responsibilities of TDCJ Supervisor



Training Circular
TDCJ Risk Management Department
Volume 12 Issue 10
October 2012

Jackie Edwards
Director, Administrative Review and Risk Management

Shannon Kersh
Manager II
Review and Standards

Robert C. Warren
Risk Management Specialist V
Risk Management

The *Training Circular*, a publication of the TDCJ Risk Management Department, is published monthly in an effort to promote and enhance risk management awareness on issues relating to TDCJ employees. Design and layout of the Training Circular is performed by Robert C. Warren, Risk Management. Comments, suggestions and safety related items are welcome. Send suggestions to:

Robert C. Warren
Risk Management Department
1060 Hwy 190 East
Huntsville, Texas 77340
or,
robert.c.warren@tdcj.state.tx.us

All items received become property of the Risk Management Department unless otherwise agreed and are subject to be rewritten for length and clarity. Permission is hereby granted to reprint articles, provided source is cited.